




**BUREAU
VERITAS**

Certificate of Conformity

Certificate No.: 1788AP1226N033005
Equipment: Hybrid inverter
Brand Name:  Growatt
Test Model No.: Growatt SPH3000, Growatt SPH3600, Growatt SPH4000,
Growatt SPH4600, Growatt SPH5000, Growatt SPH6000
Applicant: Shenzhen Growatt New Energy Technology Co., Ltd
1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28,
GuangHui Road, LongTeng Community, Shiyang Street, Baoan District,
Shenzhen, P.R.China
Report No.: PV171226N033

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with EN 50438:2013 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards

EN 50438:2013

Requirements for microgenerating plants to be connected in parallel with public low-voltage distribution networks

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

The generators Growatt SPH4000, Growatt SPH4600, Growatt SPH5000 and Growatt SPH6000 are rated > 16A per phase. However all requirements of the EN 50438:2013 are fulfilled. At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.



Name: Ted Wu
Senior Manager/ PV Inverter Team
Date: 2018-05-31

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.